

# Model ACVV-300-FF

File Number: EX28272

## COMPANY

### Sentry Sprinklers Owned by GLC Fire Systems Inc

10967 LAKE UNDERHILL RD, UNIT 102  
 ORLANDO, FL 32825 United States

## MODEL INFO

ACVV-300-FF  
 Alarm Valve

PRODUCT INFORMATION								
Body Type	Nom Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Supply Pressure Type	Alarm Device Type	Alarm Device Model	Retard Chamber Model	Installed Position
Globe	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	Flange	300 (2068)	Variable	Water motor gong	WMG-300	RC-300	Vertical
Globe	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	Flange	300 (2068)	Variable	Electric pressure switch	UL Listed (VOXZ)	RC-300	Vertical
Globe	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	Flange	300 (2068)	Constant	Water motor gong	WMG-300	Not Applicable	Vertical
Globe	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	Flange	300 (2068)	Constant	Electric pressure switch	UL Listed (VOXZ)	Not Applicable	Vertical

## GENERAL

### Installation Limitations

End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."