

Sprinkler System Components | Water Motor Gongs | **Waterflow Alarm System Valves**

Models ACVV-300GG, ACVV-300FF, ACVV-300FG and ACVV-300GF

Product Description

Model No	Description	Valve Size		Rated Working Pressure		End Connection	Remarks
		in	(mm)	psi	(kPa)		
ACVV-300-GG	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Grooved x Grooved	a, b, c
ACVV-300-FF	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flanged x Flanged	a, b, c
ACVV-300-FG	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flanged x Grooved	a, b, c
ACVV-300-GF	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Grooved x Flanged	a, b, c

Remarks:

- a. Resilient seat
- b. FM Approved for Vertical Installations Only
- c. Approved for use with Sentry Sprinklers Retarding Chamber RC-300

Details

Category	Waterflow Alarm System Valves
Class of Work	1041 - Alarm Check Valves
Approval Standard	FM 1041 - Alarm Check Valves
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc.
 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825
 United States of America
<http://sentrysprinklers.com>

Cookies help us improve your website experience. By using our website, you agree to our use of cookies.

Confirm