F Approvals

Valves | Single Check Valves | Check Valves, Single

Model 7000

Product Description

	Model No	Description	Valve Size		Rated Working Pressure		Remarks
			in	(mm)	psi	(kPa)	Remarks
	7000	Swing Check Valve, Flanged	N/A through N/A	(2 through 12)	300	(2065)	a, b

Remarks:

- a.) For use in horizontal and vertical installations
- b.) Resilient Seated Valves

Details

Category	Check Valves, Single
Class of Work	1210 - Single Check Valves
Approval Standard	FM 1210 - Swing Check Valves
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc.

10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825 United States of America

http://sentrysprinklers.com