

FM Approvals

Other Fire Protection Products | Fire Hydrants (Dry Barrel Type) | **Hydrants, Dry Barrel**

Model DH68

Product Description

Model DH68, Traffic Type

Product Specification

Size		# of Hose Outlets	Hose Outlet Size		Pumper Connection Size		Rated Working Pressure		Remarks
in	(mm)		in	(mm)	in	(mm)	psi	(kPa)	
5 1/4	(133)	2	2 1/2	(64)	4	(102)	250	(1720)	a
5 1/4	(133)	2	2 1/2	(64)	4 1/2	(114)	250	(1720)	a

Remarks:

a.) Available with 6-inch NPS mechanical or flanged elbow inlet connection.

Details

Category	Hydrants, Dry Barrel
Class of Work	1510 - Hydrants(Dry Brl Ty), Pvt FS
Approval Standard	FM 1510 - Fire Hydrant (Dry Barrel Type) for Private Fire Service
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc.
 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825
 United States of America
<http://sentrysprinklers.com>