F Approvals

Valves | Water Control Valves (OS&Y and NRS Gate Valves) | Gate Valves, Inside Screw

Model NRSP-6000

Product Description

Resilient Seated Gate Valves. 14 through 24 in. NPS. Available with the following end connections and rated working pressures:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	End connection
NRSP-6000	14, 16, 18, 20, 24	(350, 400, 450, 500, 600)	250	(1720)	Flange × Flange (ANSI, BS10, EN1092)
NRSP-6000	14, 16, 18, 20, 24	(350, 400, 450, 500, 600)	200	(1375)	Flange × Flange (ANSI, BS10, EN1092)

Details

Category	Gate Valves, Inside Screw
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc. 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825 United States of America http://sentrysprinklers.com