

FM Approvals

Sprinkler System Components | Indicator Posts | **Indicator Posts**

Model PI-6030

Product Description

Model PI-6030. Wall type.

Details

Category	Indicator Posts
Class of Work	1110 - Indicator Posts
Approval Standard	FM 1110 - Indicator Posts
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc.
 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825
 United States of America
<http://sentrysprinklers.com>