

FM Approvals

Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

SY8022

Details

Category	Non-Storage Sprinklers
Class of Work	2017 - AS, Control Mode, Pendent
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Coverage Type	Standard
Type	Pendent
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Brass, Chrome
Temp. Rating (°F)	135, 155, 175, 200
Temp. Rating (°C)	57, 68, 79, 93
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc.
 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825
 United States of America
<http://sentrysprinklers.com>