

# FM Approvals

Sprinklers | Non-Storage Sprinklers | **Non-Storage Sprinklers**

## SY8132

### Details

<b>Category</b>	Non-Storage Sprinklers
<b>Class of Work</b>	2012 - AS, Control Mode, Sidewall
<b>Approval Standard</b>	FM 2000 - Automatic Sprinklers for Fire Protection
<b>Certification Type</b>	FM Approved
<b>K</b>	5.6
<b>K (metric)</b>	80
<b>Coverage Type</b>	Standard
<b>Type</b>	Horizontal Sidewall
<b>Response</b>	QR - Quick Response
<b>Element</b>	3 mm
<b>NPT (in.)</b>	1/2
<b>Finish</b>	Brass, Chrome, Polyester
<b>Temp. Rating (°F)</b>	155, 175, 200
<b>Temp. Rating (°C)</b>	68, 79, 93
<b>Sprinkler Category</b>	Non Storage
<b>Use with Vacuum System</b>	No
<b>Grooved Connection</b>	No
<b>Listing Country</b>	United States of America

### Company

Sentry Sprinklers by GLC Fire Systems Inc.  
 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825  
 United States of America  
<http://sentrysprinklers.com>