F Approvals

Valves | Indicating Valves (Butterfly or Valve Type) | Indicating Valves, Butterfly or Ball Type

Models TD-3000, GD-3000, TB-3100, GB-3100

Product Description

Model No	Description	Valve Size		Rated Working Pressure		- Remarks
		mm	(in)	psi	(kPa)	Remarks
TD-3000	Butterfly Valve, Threaded Ends	25, 32, 40, 50, 65	(1, 1 1/4, 1 1/2, 2, 2 1/2)	175	(1205)	a, b, c
TB-3100	Butterfly Valve, Threaded Ends	25, 32, 40, 50, 65	(1, 1 1/4, 1 1/2, 2, 2 1/2)	175	(1205)	a, b, c
GD-3000	Butterfly Valve, Grooved Ends	50, 65	(2, 2 1/2)	175	(1205)	a, b, c
GB-3100	Butterfly Valve, Grooved Ends	50, 65	(2, 2 1/2)	175	(1205)	a, b, c

Remarks:

- a. Available with dual supervisory switches.
- b. FM Approved for indoor and outdoor service.
- c. FM Approved for aboveground installations only.

Details

Category	Indicating Valves, Butterfly or Ball Type
Class of Work	1112 - Indicating Valves
Approval Standard	FM 1112 - Indicating Valves (Butterfly or Ball Type)
Certification Type	FM Approved
Listing Country	United States of America

Company

Sentry Sprinklers by GLC Fire Systems Inc. 10967 Lake Underhill Road, Unit 102, Orlando , Florida 32825 United States of America http://sentrysprinklers.com