



Model OSY-6000

File Number: EX28584


COMPANY

Sentry Sprinklers Owned by GLC Fire Systems Inc
10967 LAKE UNDERHILL RD, UNIT 102
ORLANDO, FL 32825 United States

MODEL INFO

OSY-6000

GENERAL			
Pattern	Size, in.	End Configuration	Rated Pressure, psig (kPa)
OS&Y	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12	F by F,F by G,G by G	300 (2068)



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."