

# SIN SY8051

File Number: EX28273

## COMPANY

Sentry Sprinklers Owned by GLC Fire Systems Inc  
 10967 LAKE UNDERHILL RD, UNIT 102  
 ORLANDO, FL 32825 United States


## SIN INFO

SY8051  
 Glass Bulb Type

ATTRIBUTES				
Response Type	Sprinkler Type	Nom K-Factor, gpm/vpsi (L/min/vbar)	System Working Pressure	Corrosion Resistant
SR	Standard-Spray Sprinklers, Upright And Pendent	5.6 (80)	175 psig (1.2 Mpa)	Not Available

GENERAL
<b>Inlet Connection</b>
1/2 in. NPT

STANDARD-SPRAY SPRINKLERS, UPRIGHT AND PENDENT		
Type	Sprinkler Temp Rating, °F (°C)	Cover Temp Rating, °F (°C)
Conc. Pendent	135 (57), 155 (68), 175 (79), 200 (93)	135 (57), 155 (68)



The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."